

I-SEM

LCF Short Day Clock Change Bulletin

Version 1.2



COPYRIGHT NOTICE

All rights reserved. This entire publication is subject to the laws of copyright. This publication may not be reproduced or transmitted in any form or by any means, electronic or manual, including photocopying without the prior written permission of EirGrid plc and SONI Limited.

DOCUMENT DISCLAIMER

This document is only intended as a guide to assist participants in understanding the Limited Communication Failure on the short day clock change. It is not, and is not meant to be, a comprehensive description of the TSC and/or a substitute for the detailed provisions of the TSC (including the Agreed Procedures). Prior to taking business decisions, participants are advised to seek separate and independent opinion in relation to the matters covered by this guide and should not rely solely upon data and information contained herein. EirGrid plc and SONI Limited give no warranties or representations, expressed or implied, of any kind with respect to the contents of this document, including, without limitation, its quality, accuracy and completeness. EirGrid plc and SONI hereby exclude, to the fullest extent permitted by law, all and any liability for any loss or damage howsoever arising from the use of this document or any reliance on the information it contains. Use of this document and the information it contains is at the user's sole risk.

1 Document Version History

Version	Date	Author	Description of changes
1.0	26/03/2019	Trading Operations, SEMO	Initial Release
1.1	24/03/2020	Trading Operations, SEMO	Second Release
1.2	19/03/2021	Trading Operations, SEMO	Third Release

2 Introduction

This I-SEM Limited Communications Failure (LCF) short day clock change bulletin seeks to provide clarity on how to use the LCF XML generator 'short day' tool for the short day clock change. In this document we will provide an example of how to use the tool to create:

- Physical Notifications
- Simple Commercial Offer Data
- Forecast Availability

This document is only intended to aid participants in case they experience an LCF on the short day clock change day (e.g. 28/03/2021). An LCF is where a Participant cannot access the Balancing Market via TYPE2 (BMI) or TYPE3 (Web service) where applicable. If a participant experiences an LCF, please refer to [Section 3 Useful Links](#) below. This document does not serve as a guide for participant Balancing Market submissions; for general queries, participants should consult the I-SEM Technical Specification (see [Section 3 Useful Links](#)).

The clock change for 2021 will occur on the 28th March 2021 at 1am, where an hour will be missing. This means that at 01:00, the hour will be incremented by one and will therefore be referred to as 02:00.

2.1 Physical Notifications

This section describes how to create Physical Notifications (PN) using the LCF 'short day' tool.

- PN period segments are to be populated by the participant. **Note:** The participant will need to seed the initial PN starting MW value to ensure that a continuous curve is maintained.
- From 23:00 (Local Time) 27 March – 00:30 (Local Time) 28 March period segments are to be submitted as normal as seen in the below example:

Start Time	End Time	Start MW	End MW
27/03/2021 23:00	27/03/2021 23:30	0	0
27/03/2021 23:30	28/03/2021 00:00	0	0
28/03/2021 00:00	28/03/2021 00:30	0	0
28/03/2021 00:30	28/03/2021 02:00	0	0
28/03/2021 02:00	28/03/2021 02:30	0	0
28/03/2021 02:30	28/03/2021 03:00	0	0
28/03/2021 03:00	28/03/2021 03:30	0	0
28/03/2021 03:30	28/03/2021 04:00	0	0

- In the hour immediately following Imbalance Settlement Period, the clock change occurs and an adjustment from 01:00 to 02:00 will occur.
- At 01:00 (Local time) on 28 March, the time will be incremented to 02:00 (Local Time) on 28 March. As a result, period segments are to be submitted without the hour of 01:00 to 02:00. In order to maintain a continuous curve, a PN segment that would on normal days be submitted as 00:30-01:00 should be submitted as 00:30 (Local Time) on 28 March to 02:00 (Local Time) on 28 March.

Resource Name	GU_412345	<<<<	<<<<	<<<<
Start Time	End Time	Start MW	End MW	
27/03/2021 23:00	27/03/2021 23:30	0	0	
27/03/2021 23:30	28/03/2021 00:00	0	0	
28/03/2021 00:00	28/03/2021 00:30	0	0	
28/03/2021 00:30	28/03/2021 02:00	0	0	
28/03/2021 02:00	28/03/2021 02:30	0	0	
28/03/2021 02:30	28/03/2021 03:00	0	0	
28/03/2021 03:00	28/03/2021 03:30	0	0	
28/03/2021 03:30	28/03/2021 04:00	0	0	

- PN segments for the 28th March from 02:00 onwards Local Time are to be submitted as for normal days, as seen in below screenshot.

Start Time	End Time	Start MW	End MW
27/03/2021 23:00	27/03/2021 23:30	0	0
27/03/2021 23:30	28/03/2021 00:00	0	0
28/03/2021 00:00	28/03/2021 00:30	0	0
28/03/2021 00:30	28/03/2021 02:00	0	0
28/03/2021 02:00	28/03/2021 02:30	0	0
28/03/2021 02:30	28/03/2021 03:00	0	0
28/03/2021 03:00	28/03/2021 03:30	0	0
28/03/2021 03:30	28/03/2021 04:00	0	0
28/03/2021 04:00	28/03/2021 04:30	0	0
28/03/2021 04:30	28/03/2021 05:00	0	0
28/03/2021 05:00	28/03/2021 05:30	0	0
28/03/2021 05:30	28/03/2021 06:00	0	0
28/03/2021 06:00	28/03/2021 06:30	0	0
28/03/2021 06:30	28/03/2021 07:00	0	0
28/03/2021 07:00	28/03/2021 07:30	0	0
28/03/2021 07:30	28/03/2021 08:00	0	0
28/03/2021 08:00	28/03/2021 08:30	0	0
28/03/2021 08:30	28/03/2021 09:00	0	0
28/03/2021 09:00	28/03/2021 09:30	0	0
28/03/2021 09:30	28/03/2021 10:00	0	0
28/03/2021 10:00	28/03/2021 10:30	0	0
28/03/2021 10:30	28/03/2021 11:00	0	0
28/03/2021 11:00	28/03/2021 11:30	0	0

Additional Notes:

- No PN submission can span the clock change boundary time at 01:00 IST (incremented to 02:00 IST).

Start Time	End Time	Start MW	End MW
27/03/2021 23:00	27/03/2021 23:30	0	0
27/03/2021 23:30	28/03/2021 00:00	0	0
28/03/2021 00:00	28/03/2021 00:30	0	0
28/03/2021 00:30	28/03/2021 02:00	0	0
28/03/2021 02:00	28/03/2021 02:30	0	0
28/03/2021 02:30	28/03/2021 03:00	0	0
28/03/2021 03:00	28/03/2021 03:30	0	0
28/03/2021 03:30	28/03/2021 04:00	0	0

2.2 Forecast Availability

This section describes how to create forecast availability using the LCF ‘short day’ tool:

For the Short Day, cells are automatically populated with 00:30 (Local Time) 28 March – 02:00 (Local Time) 28 March to take account of the missing hour

Resource Name		GU_412345	<<<<	<<<<	<<<<
Start Time	End Time	Fuel Flag (P or S)	Min Output	Min Stable Generation	Max Availability
27/03/2021 23:00	27/03/2021 23:30	P	0	0	100
27/03/2021 23:30	28/03/2021 00:00	P	0	0	100
28/03/2021 00:00	28/03/2021 00:30	P	0	0	100
28/03/2021 00:30	28/03/2021 02:00	P	0	0	100
28/03/2021 02:00	28/03/2021 02:30	P	0	0	100
28/03/2021 02:30	28/03/2021 03:00	P	0	0	100
28/03/2021 03:00	28/03/2021 03:30	P	0	0	100

2.3 Simple Offer Data

This section describes how to use the tool to create the LCF ‘short day’ tool for Simple Offer Data.

- The “Long Day hour submission” flag must be equal to “No”
- Additionally, if start time is 02:00 GMT “Long Day hour submission” flag must be equal to “No”

Additional Notes:

- No segment can cross the clock change boundary 01:00 IST (Irish Summer Time). As per the PNs and Forecast Availability, Simple COD must be entered as 00:30 (Local Time) 28 March – 02:00 (Local Time) 28 March if covering the period during which the time change occurs.

1	
Resource Name	GU_412345
Resource Type	GEN <<<<
Start Time	28/03/2021 00:30 <<<<
End Time	28/03/2021 02:00 <<<<
Long Day Hour Submission?	No <<<<

Incremental Curve	Price (#/MWh)	Quantity (MW)
1	50	10
2	100	20
3	150	30
4	200	40
5		
6		
7		
8		
9		
10		

Decremental Curve	Price (#/MWh)	Quantity (MW)
1	45	10
2	90	20
3	135	30
4	180	40

3 Useful Links*

Document	URL
LCF 'Short Day' Tool	https://www.sem-o.com/documents/general-publications/LCF-Short-Day-Tool.zip
LCF Process Document	https://www.sem-o.com/documents/general-publications/LCF-Offer-Data-Procedure-Participant-Guide-Version-1.4.pdf
I-SEM Technical Specification Release 9.4	https://www.sem-o.com/documents/general-publications/I-SEM-Technical-Specification-(ITS)-Release-9.4.zip

*Open in Chrome if any issues arise.